






Sinergy III Series UPS 1000 VA Low Voltage







Model	ACDEF1000-11
Part Number	17101-01R
Туре	Sinergy III
Power Rating	1000 VA / 900 W
Тороlоду	On-Line Double Conversion
Heat Dissipation (BTU/Hour)	520 at 100% Load
Input Voltage (Nominal) Range	100-120 VAC 90-150 VAC
Input Frequency	50/60 Hz ±4 (Auto Sense on Start-Up)
Input Power Factor	>0.95
Input Current THD	<9.0%
Efficiency	>84.0%
Output Voltage	120 VAC (Default) 100/110/115 VAC (Selectable)
Output Current	8.3 A (Default) 10.0/9.1/8.7 A (Selectable)
Voltage Regulation	±1.0%
Overload Online Mode	100-105%: Continuous; Warning Only 105-130%: 2 Minutes 130-200%: 10 Seconds >200%: 250 Milliseconds
Overload Battery Mode	100-105%: Continuous; Warning Only 105-130%: 10 Seconds >130%: 250 Milliseconds
Overload Bypass Mode	100-110%: Continuous; Warning Only 110-120%: 30 Minutes 120-130%: 10 Minutes >130%: 1 Minute
Battery Voltage (Float / Nominal)	27.4/24.0 VDC
Charger Current	1.0 A
Backup Time (Full Load)	>3.5 Minutes
Communications Interface	USB / RS-232
Shipping Weight	37.0 lbs. / 16.8 kg.



SPECIFICATIONS

Front Panel Controls	Internal Batteries
 I. ON / MUTE - UP KEY (Previous Selection) 2. SELECT - DOWN KEY (Next Selection) 3. OFF / ENTER - CONFIRM KEY Front Panel Display Load <u> <u> </u></u>	Internal Batteries User Hot-Swappable (See Instruction Manual) Type - 12 V, 8.5 AH Quantity - 2 Batteries Recharge time - 12 Hours to 100% Environmental Temperature: 0 to 40°C (32 to 104°F) Operating -20 to 50°C (-40 to 122°F) Shipment, Storage Humidity: <00% Non-Condensing (Operating, Shipment, Storage) Altitude: <1000m Operating, No De-Rating >1000m De-Rate Output 1% per 100m Safety Agency and EMC Compliance All units are listed by UL, and marked with the UL/cUL marking. Product Listings UL1778 cUL to CSA22.2 No.107.1 Product Compliances FCC Part 15J Class A IEC61000-4-2, Electrostatic Discharge IEC61000-4-3, Radiated Electromagnetic Field Immunity IEC61000-4-4, Electrical Fast Transient/Burst Immunity IEC61000-4-6, CS IEC61000-4-8, Power Frequency Magnetic Field IEC61000-2-2, Low Frequency Signal RoHS

Warranty/Support: Sinergy III Series products (hereafter referred to as "Product") are warranted to be free from defects in material and workmanship for two (2) years from date of shipment from POWERVAR, on the chassis & electronic components and two (2) years from date of shipment from POWERVAR on the batteries. This warranty is limited to repairing, replacing, or refurbishing, at POWERVAR's option, any defective component, circuit board or module within the Product. This warranty will include, at POWERVAR's sole discretion, on-site service or POWERVAR depot service. See the Limitations of Warranty section below for additional limitations & exclusions.

Battery Life Disclaimer: POWERVAR's standard battery warranty applies only to UPS and UPM products which are continuously connected to AC mains power, except during utility power outages. Products which are regularly and intentionally disconnected from AC mains power will experience battery discharge/charge cycles potentially far more numerous than those for which the battery was designed. As a result, products used in such applications will experience substantially reduced battery life. For that reason, POWERVAR's standard battery warranty does not apply for applications in which the UPS or UPM product is regularly and intentionally disconnected from AC mains power. POWERVAR UPS and UPM products used in such applications shall receive a 90 day warranty on batteries.

POWERVAR, Inc. - 1450 Lakeside Drive, Waukegan, IL 60085 POWERVAR, Ltd. - Unit 5 Birch, Kembrey Park, Swindon, Wiltshire, UK SN2 8UU